



# FREDERICK COUNTY GOVERNMENT

## DIVISION OF FINANCE

*Erin M. White, CPA, Acting Director*

### *Department of Procurement & Contracting*

*Diane L. George, CPPB, Director*

Winchester Hall, 12 East Church Street  
Frederick, Maryland 21701

[www.FrederickCountyMD.gov](http://www.FrederickCountyMD.gov)

O: 301-600-1069 F: 301-600-2521

### Commissioners

Blaine R. Young  
*President*

C. Paul Smith  
*Vice President*

Billy Shreve  
David P. Gray  
Kirby Delauter

Lori L. Depies, CPA  
*County Manager*

**May 8, 2014**

**IFB# 14-069-CP**

**New Design Water Treatment Plant 1**

**Replacement of Butterfly Valve Motor Actuators and Integration with Plant Controls**

### **Addendum No. 2**

This addendum contains revisions, clarifications, and information pertinent to the bid documents of the referenced project and shall supplement, amend, and become part of the procurement documents for the title project and contract. All bids shall be based on this Addendum, in accordance with the bid documents.

This Addendum consists of this sheet only.

Acknowledgment of this addendum shall be made on the Proposal Form, including addendum number and date. Failure to acknowledge addendum may subject the bidder to disqualification.

**Contractors that did not attend the conference will not be eligible for award of a contract.**

***Bids will be received until 3:00 PM local time, May 15, 2014.***

Except as noted herein, all terms and conditions of the document referenced, as heretofore changed, remain unchanged and in full force and effect.

Tim Kepp, Project Manager

### **CLARIFICATIONS/ADDITIONS**

Integral disconnects or a local external disconnect are needed and both are acceptable.

The selector switch for local or remote control shall be located with the remote push button station.

Phase correction is NOT needed for the actuator.

**End of Addendum #2**